



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

contact no.: 033- 5014269, 09173058082

TEST REPORT

Physico - Chemical Examination of Water

TR NO.: CHEM-16-0672

Name of Customer: **DUMALAG WATER DISTRICT**
Address: Dumalag, Capiz
Sample Description: Clear / Without Sediment
Time of Sampling: 07:00 A.M
Sample Source/Location: Faucet


Date Submitted: December 28, 2016
Date Analyzed: December 29, 2016
Date Reported: January 04, 2017
Page: 1 of 1

TEST PERFORMED	METHOD	RESULTS	ACCEPTABLE VALUES	REMARKS
Color (Apparent color)	Colometric Method	2	10 color units	PASSED
Total dissolved solids (mg/L)	Gravimetric Method, dried @ 180 ^o C	75.60	500 <10 for product that undergone osmosis / distillation process	PASSED
Electrical Conductivity (us/cm)	Electrical Conductivity Meter	262.60		
Turbidity	Turbidimetry	0.39	5 NTU	PASSED
pH	Glass Electrode Mthod	7.41	6.5 - 8.5 5 - 7 for product water undergone reverse osmosis	PASSED
Chloride (mg/L)	Argentometric Method	5	250 mg/L	PASSED
Total Hardness	Titrimetic Method	120	300 as CaCO ₃	PASSED
Calcium (mg/L)		104		
Magnesium (mg/L)		16		
Iron (mg/L)	Phenanthroline Method	nil	1.0 mg/L	PASSED
Nitrate (mg/L)	Spectrophotometric Method	nil	50 mg/L	PASSED
Nitrite (mg/L)	Diazotization Method	nil	3 mg/L	PASSED
Sulfates (mg/L)	Turbidimetric Method	3.289	250 mg/L	PASSED
Odor	Threshold Odor Test (Sensory Evaluation Technique)	No odor detected	No objectionable odor	PASSED

References: Standard Methods for the Examination of Water and Waste Water 21st Edition 2005
Philippine National Standards for Drinking Water 2007

Note: 1. "Results relate to samples as received"
2. Test done is sub-contracted to NPCC-ADL (DOH ACCREDITATION #: 06-007-127LW-2)

Certified Correct:


HELEN P. SUBRADIL, RChE
Laboratory Head

**This test report shall not be reproduced except in full without the written approval of the laboratory.*

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry. Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com
contact no.: 033- 5014269, 09173058082

TEST REPORT

Physico - Chemical Examination of Water

TR NO.: CHEM-16-0160

Name of Customer: **DUMALAG WATER DISTRICT**
Address: Dumalag, Capiz
Sample Description: Clear / Without Sediment
Time of Sampling: 04:44 P.M.
Sample Source/Location: Product/Faucet


Date Submitted: March 12, 2016
Date Analyzed: March 14, 2016
Date Reported: March 17, 2016
Page: 1 of 1

TEST PERFORMED	METHOD	RESULTS	ACCEPTABLE VALUES	REMARKS
Color (Apparent color)	Colometric Method	2	10 color units	PASSED
Total dissolved solids (mg/L)	Gravimetric Method, dried @ 180 ^o C	81.40	500 <10 for product that undergone osmosis / distillation process	PASSED
Electrical Conductivity (us/cm)	Electrical Conductivity Meter	271.20		
Turbidity	Turbidimetry	1.33	5 NTU	PASSED
pH	Glass Electrode Method	7.25	6.5 - 8.5 5 - 7 for product water undergone reverse osmosis	PASSED
Chloride (mg/L)	Argentometric Method	19	250 mg/L	PASSED
Total Hardness	Titrimetic Method	128.13	300 as CaCO ₃	PASSED
Calcium (mg/L)		120.13		
Magnesium (mg/L)		8.01		
Iron (mg/L)	Phenanthroline Method	nil	1.0 mg/L	PASSED
Nitrate (mg/L)	Spectrophotometric Method	nil	50 mg/L	PASSED
Nitrite (mg/L)	Diazotization Method	nil	3 mg/L	PASSED
Sulfates (mg/L)	Turbidimetric Method	4.43	250 mg/L	PASSED
Odor	Threshold Odor Test (Sensory Evaluation Technique)	No odor detected	No objectionable odor	PASSED

References: Standard Methods for the Examination of Water and Waste Water 21st Edition 2005
Philippine National Standards for Drinking Water 2007

Note: 1. "Results relate to samples as received"
2. Test done is sub-contracted to NPCC-ADL (DOH ACCREDITATION #: 06-007-127LW-2)

Certified Correct:


HELEN P. SUBRADIL, RChE
Laboratory Head

**This test report shall not be reproduced except in full without the written approval of the laboratory.*

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry. Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.




Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com



TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-078A

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 04:40 P.M.

Sample Source/Location: Product/Faucet

Date Submitted: January 20, 2016

Date Analyzed: January 21, 2016

Date Reported: January 26, 2016

Page: 1 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-078A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.


Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
 Accreditation Number: 06-051-14-LW-2
 Jalandoni Estate, Lapuz Iloilo City
 email add: astslabiloilo@yahoo.com



TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-078B

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: January 20, 2016

Time of Sampling: 04:20 P.M.

Date Analyzed: January 21, 2016

Sample Source/Location: Product/Faucet

Date Reported: January 26, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-078B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.


Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com



TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-078C

Name of Customer: DUMALAG WATER DISTRICT (SITIO ANGEL)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 04:30 P.M.

Sample Source/Location: Product/Faucet

Date Submitted: January 20, 2016

Date Analyzed: January 21, 2016

Date Reported: January 26, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-078C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	2	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT Bacteriological Examination of Water

TR NO.: MIC-16-0169A

Name of Customer: **DUMALAG WATER DISTRICT (SITIO SUHOT)**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 04:40 P.M.

Sample Source/Location: Product/Faucet

Date Submitted: February 10, 2016

Date Analyzed: February 10, 2016

Date Reported: February 15, 2016

Page: 1 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0169A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChe

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0169B

Name of Customer: **DUMALAG WATER DISTRICT (BRGY. DOLORES)**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: February 10, 2016

Time of Sampling: 04:10 P.M.

Date Analyzed: February 10, 2016

Sample Source/Location: Product/Faucet

Date Reported: February 15, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0169B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0169C

Name of Customer: DUMALAG WATER DISTRICT (SITIO ANGEL)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: February 10, 2016

Time of Sampling: 04:40 P.M.

Date Analyzed: February 10, 2016

Sample Source/Location: Product/Faucet

Date Reported: February 15, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0169C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	2	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0288C

Name of Customer: DUMALAG WATER DISTRICT (SITIO AYUYAN)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 04:40 P.M.

Sample Source/Location: Product/Faucet

Date Submitted: March 12, 2016

Date Analyzed: March 12, 2016

Date Reported: March 16, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0288C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	2	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0288B

Name of Customer: **DUMALAG WATER DISTRICT (SITIO SUHOT)**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 04:10 P.M.

Sample Source/Location: Product/Faucet

Date Submitted: March 12, 2016

Date Analyzed: March 12, 2016

Date Reported: March 16, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0288B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	2	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0288A

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 04:40 P.M.

Sample Source/Location: Product/Faucet

Date Submitted: March 12, 2016

Date Analyzed: March 12, 2016

Date Reported: March 16, 2016

Page: 1 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0288A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0406C

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: April 09, 2016

Time of Sampling: 05:30 A.M.

Date Analyzed: April 09, 2016

Sample Source/Location: Faucet

Date Reported: April 13, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0406C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0406B

Name of Customer: DUMALAG WATER DISTRICT (SITIO AYUYAN)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: April 09, 2016

Time of Sampling: 06:15 A.M.

Date Analyzed: April 09, 2016

Sample Source/Location: Faucet

Date Reported: April 13, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0406B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	2	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0406A

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: April 09, 2016

Time of Sampling: 06:40 A.M.

Date Analyzed: April 09, 2016

Sample Source/Location: Faucet

Date Reported: April 13, 2016

Page: 1 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0406A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737


Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChe

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0560C

Name of Customer: **DUMALAG WATER DISTRICT (SITIO ANGEL)**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 05:30 A.M.

Sample Source/Location: Faucet

Date Submitted: May 13, 2016

Date Analyzed: May 13, 2016

Date Reported: May 17, 2016

Page: 3 of 3


RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0560C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	


Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0792C

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: July 05, 2016

Time of Sampling: 07:40 A.M.

Date Analyzed: July 05, 2016

Sample Source/Location: Faucet

Date Reported: July 09, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0792C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0792B

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: July 05, 2016

Time of Sampling: 07:40 A.M.

Date Analyzed: July 05, 2016

Sample Source/Location: Faucet

Date Reported: July 09, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0792B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChe

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0792A

Name of Customer: **DUMALAG WATER DISTRICT (SITIO ANGEL)**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: July 05, 2016

Time of Sampling: 07:40 A.M.

Date Analyzed: July 05, 2016

Sample Source/Location: Faucet

Date Reported: July 09, 2016

Page: 1 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0792A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0961A

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: August 10, 2016

Time of Sampling: 06:40 A.M.

Date Analyzed: August 10, 2016

Sample Source/Location: Faucet

Date Reported: August 15, 2016

Page: 1 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0961A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-0961C

Name of Customer: DUMALAG WATER DISTRICT (SITIO ANGEL)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 07:10 A.M.

Sample Source/Location: Faucet

Date Submitted: August 10, 2016

Date Analyzed: August 10, 2016

Date Reported: August 15, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0961C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	7	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737


Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT Bacteriological Examination of Water

TR NO.: MIC-16-0961B

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: August 10, 2016

Time of Sampling: 06:55 A.M.

Date Analyzed: August 10, 2016

Sample Source/Location: Faucet

Date Reported: August 15, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-0961B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	6	


Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012


Note: "Results relate to samples as received"


Analyzed by:

Reviewed by:

Approved by:


ROXANNE E. JAGOLINA, RMT
Analyst


LAIKA E. SUAREZ, RMT
Analyst


HELEN P. SUBRADIL, RChE
Laboratory Head

PRC Reg #: 65737

PRC Reg #: 0070389

PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01103A

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: September 08, 2016

Time of Sampling: 06:00 A.M.

Date Analyzed: September 08, 2016

Sample Source/Location: Faucet

Date Reported: September 12, 2016

Page: 1 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01103A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	6	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012


Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst


PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChe
Laboratory Head

PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT Bacteriological Examination of Water

TR NO.: MIC-16-01103B

Name of Customer: **DUMALAG WATER DISTRICT (SITIO AYUYAN BRGY. SITIO ANGEL)**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: September 08, 2016

Time of Sampling: 06:30 A.M.

Date Analyzed: September 08, 2016

Sample Source/Location: Faucet

Date Reported: September 08, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01103B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737


Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engaged with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01103C

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: September 08, 2016

Time of Sampling: 05:30 A.M.

Date Analyzed: September 08, 2016

Sample Source/Location: Faucet

Date Reported: September 12, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01103C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	2	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737


Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-051-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01283A

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 06:05 A.M.

Sample Source/Location: Faucet

Date Submitted: October 14, 2016

Date Analyzed: October 14, 2016

Date Reported: October 18, 2016

Page: 1 of 3


RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01283A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	3	


Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.


We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in

seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01283B

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 06:11 A.M.

Sample Source/Location: Faucet

Date Submitted: October 14, 2016

Date Analyzed: October 14, 2016

Date Reported: October 18, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01283B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	


Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.


We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in

seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-051-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT Bacteriological Examination of Water

TR NO.: MIC-16-01283C

Name of Customer: **DUMALAG WATER DISTRICT (STO. ANGEL)**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 06:27 A.M.

Sample Source/Location: Faucet

Date Submitted: October 14, 2016

Date Analyzed: October 14, 2016

Date Reported: October 18, 2016


Page: 3 of 3

RESULT OF ANALYSIS


SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01283C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	4	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012
Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:



HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.
Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-052-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01406A

Name of Customer: DUMALAG WATER DISTRICT (SITIO AYUYAN)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 06:00 A.M.

Sample Source/Location: Faucet

Date Submitted: November 10, 2016

Date Analyzed: November 10, 2016

Date Reported: November 14, 2016


Page: 1 of 3

RESULT OF ANALYSIS


SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01406A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	7	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012
Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-052-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01406B

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: November 10, 2016

Time of Sampling: 06:20 A.M.

Date Analyzed: November 10, 2016

Sample Source/Location: Faucet

Date Reported: November 14, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01406B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	8	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:

ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:

LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:

HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-052-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01406C

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: November 10, 2016

Time of Sampling: 06:35 A.M.

Date Analyzed: November 10, 2016

Sample Source/Location: Faucet

Date Reported: November 14, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01406C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	5	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737


Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-052-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT Bacteriological Examination of Water

TR NO.: MIC-16-01543A

Name of Customer: DUMALAG WATER DISTRICT (BRGY. DOLORES)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 06:20 A.M.

Sample Source/Location: Faucet

Date Submitted: December 08, 2016

Date Analyzed: December 08, 2016

Date Reported: December 12, 2016

Page: 1 of 3


RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01543A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	5	


Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.

DOH Accreditation Number: 06-052-14-LW-2

Jalandoni Estate, Lapuz Iloilo City

email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01543B

Name of Customer: DUMALAG WATER DISTRICT (SITIO SUHOT)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: December 08, 2016

Time of Sampling: 06:34 A.M.

Date Analyzed: December 08, 2016

Sample Source/Location: Faucet

Date Reported: December 12, 2016

Page: 2 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01543B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	6	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-052-14-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-16-01543C

Name of Customer: DUMALAG WATER DISTRICT (SITIO AYUYAN)

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Date Submitted: December 08, 2016

Time of Sampling: 06:45 A.M.

Date Analyzed: December 08, 2016

Sample Source/Location: Faucet

Date Reported: December 12, 2016

Page: 3 of 3

RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-16-01543C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	5	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"

Analyzed by:


ROXANNE E. JAGOLINA, RMT

Analyst

PRC Reg #: 65737


Reviewed by:


LAIKA E. SUAREZ, RMT

Analyst

PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE

Laboratory Head

PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-003-17-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT Bacteriological Examination of Water

TR NO.: MIC-17-059A

Name of Customer: **DUMALAG WATER DISTRICT**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 06:17 A.M.

Sample Source/Location: Faucet/ Sitio Ayuyan

Date Submitted: January 12, 2017

Date Analyzed: January 12, 2017

Date Reported: January 16, 2017

Page: 1 of 3


RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-17-059A	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	6	


Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-003-17-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT Bacteriological Examination of Water

TR NO.: MIC-17-059B

Name of Customer: **DUMALAG WATER DISTRICT**
Address: Dumalag, Capiz
Sample Description: Clear / Without Sediment
Time of Sampling: 06:22 A.M.
Sample Source/Location: Faucet/ Brgy. Dolores


Date Submitted: January 12, 2017
Date Analyzed: January 12, 2017
Date Reported: January 16, 2017
Page: 2 of 3

RESULT OF ANALYSIS


SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-17-059B	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	5	

Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012
Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823


*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.



Analytical Solution and Technical Services Iloilo, Inc.

Analytical Solutions & Technical Services, Iloilo Inc.
DOH Accreditation Number: 06-003-17-LW-2
Jalandoni Estate, Lapuz Iloilo City
email add: astslabiloilo@yahoo.com

TEST REPORT

Bacteriological Examination of Water

TR NO.: MIC-17-059C

Name of Customer: **DUMALAG WATER DISTRICT**

Address: Dumalag, Capiz

Sample Description: Clear / Without Sediment

Time of Sampling: 06:35 A.M.

Sample Source/Location: Faucet/ Sitio Suhot

Date Submitted: January 12, 2017

Date Analyzed: January 12, 2017

Date Reported: January 16, 2017

Page: 3 of 3


RESULT OF ANALYSIS

SAMPLE CODE	PARAMETERS	STANDARD SPECIFICATION PNS DW 2007	RESULT	REMARKS
MIC-17-059C	TOTAL COLIFORM (MPN / 100mL)	<1.1	<1.1	PASSED
	FECAL COLIFORM (MPN / 100mL)	<1.1	<1.1	
	HPC (CFU / mL)	<500	5	


Test Method Used: Multiple Tube Fermentation, SMEWW 22nd Ed. 2012

Note: "Results relate to samples as received"


Analyzed by:


ROXANNE E. JAGOLINA, RMT
Analyst
PRC Reg #: 65737

Reviewed by:


LAIKA E. SUAREZ, RMT
Analyst
PRC Reg #: 0070389

Approved by:


HELEN P. SUBRADIL, RChE
Laboratory Head
PRC Reg #: 13823

*This test report shall not be reproduced except in full without the written approval of the laboratory.

We deliver TRUST that you can count on.

About ASTS Analytical Solutions and Technical Services Iloilo, Inc.

Our Company is mainly engage with Laboratory services in Microbiological and Chemical testing. We also conduct Seminar, Workshops and Training on ISO / IEC 17025 Laboratory Internal Audit, Proficiency Testing, Quality Assurance / Quality Control in Analytical Laboratory, Laboratory Test Methods Development and Validation, GLP and GMP, Measurement of Uncertainty in Chemistry and Microbiology and Equipment Calibration and Maintenance. We are also involved in organizing awareness seminars on regulations relevant to Analytical Laboratory analysis and Agro- industrial Operations as an effort to support the Philippine Industry.

Our Laboratories are based in Jalandoni Estate Lapuz Iloilo and General Santos City, Philippines.